

DEPARTMENT

CITY

NEW YORK, Boroughs of Manhattan and The Bronx,

No. 220 FOURTH AVENUE.

New York, Jan 1900

489

JAN 5 1900

FOR THE BOROUGH OF
MANHATTAN & THE BRONX.

Amendment to Application No. 2117

N. B. 1897

Location N.S. 7th St 207' 6" of 1st Ave

- 1 All beams shall be 3" by their respective depths
- 2 Girders shall be 8"x12" as called for in application
- 3 Columns 8" and 13" by 8" and 7" bolted together.
- 4 Floors will sustain in load of 120 lbs per sq ft.
- 5 Applicant submit detail of roof trusses.
- 6 Exterior wall shall be buttressed, see additional drawing.
7. Parlious shall be 4"x8"
8. Columns supporting exterior walls 8"x7" set upon one another bolted together.
9. Construction of Doors shall be of iron see additional drawings
- 10 Girders shall be composed of 3-12"-96 lbs.
- 11 All brickwork shall be laid in cement.
- 12 Columns shall be protected with galvanized T.C.
- 13 See additional drawing.
- 14 " " "

A. Artander

New York

Jan 11/9 1900

This is to certify that the within details
statement of specifications and a copy of the plans
relating thereto, have been submitted to the
Commissioner of Buildings for the Boroughs of
Manhattan and the Bronx and are hereby

Approved,

Commissioner of Buildings for the
Boroughs of Manhattan and the Bronx.

New York, Jan ²³ 1901 1899

Amendment to Application No. 2117

N B. 1899

Location N.S. 7th St 207' E of 1st Ave.

1. All beams shall be 3" by their respective depths.
2. Girders shall be 8x12 as called for in applications.
3. All cols of steel made up of 2"x1" ~~web~~ web and 3x3 1/2 L angles
4. First story Cols of 7"x1" web & 3x3 1/2 L angles bolted together
5. Floor will sustain live load of 120 lbs per sq ft.
6. Details of masonry basement submitted + addition iron shoes etc shown on drawings
7. Ceilings shall be 4x8
8. Cols supporting ceiling wall made of 1 1/2" steel web and 3x3 1/2 L
9. Construction of col shall be of iron see drawings as amended
10. Girders shall be of 2-20" steel beams 65 lb.
11. All brick work laid in cement.
12. All Cols shall be fireproofed with gr & c.
13. Depth of ana wall 11'0"
14. Steel beams 12" 40 lb 2 row lock bonded brick arches
15. See # 3. above.
16. Templates shall be of cast iron 1 1/4" x full ~~width~~ ^{thickness} of wall by,
17. Iron caps & shoes shall be provided see amendment on plans.
18. Shown on section etc.
- 20 ~~19~~. Addition structural work shown on amended drawing
- 19 See # 8 above.
- 21 See # 10 "
- 22 See # 13 "
23. See # 14 "
- 24 All objections answered.

New York, Jan 25 1901
 This is to certify that the within amendment of plans has been submitted to the Department of Buildings and the Board of Fire Commissioners and the same have been approved by them.
 A. C. [Signature]
 Chief Clerk of the Department of Buildings and the Board of Fire Commissioners

SM

DEPARTMENT OF BUILDINGS CITY OF NEW YORK, Boroughs of Manhattan and The Bronx,

No. 220 FOURTH AVENUE.

New York, May 15th 1900

Amendment to Application No. 2117 N. B. 1899

Location N. S. 7th St. 207' E of 1st Ave.

The general scheme for Iron Work to be amended as follows and as per drawings filed herewith.

3. 1st Story columns and cellar columns running through two stories to be made of 2-8" channels 11 $\frac{1}{2}$ " and 2 plates 9 $\times\frac{1}{2}$ " Columns which run through cellar only to be 6"0 $\times\frac{3}{4}$ " cast.
6. Girders supporting side walls to be 2-10" I's 25 $\frac{1}{2}$ ".
16. Bearing plates under roof trusses to be 12 \times 14 $\times\frac{1}{2}$ " forming part of the shoe of truss and resting on stone templets.
28. Construction of tower as per revised plan submitted herewith.
14. Size of sidewalk beams 12" I 31 $\frac{1}{2}$ " with 12" channels 20 $\frac{1}{2}$ ".
23. Where sidewalk beam comes over door, supported by 12" channel 20 $\frac{1}{2}$ ".
27. Truss details as shown on revised section submitted herewith.

I have thoroughly examined the within specifications and also the drawings relating thereto and find the same conform to the law as to construction.

Dated May 16 - 1900

R. H. Miller

5/17 1900
Arthur A. Anderson
This is to certify that the within and foregoing specifications and drawings have been submitted to the Commissioner of Buildings for the Boroughs of Manhattan and The Bronx and are hereby approved.

OK May 17 - 00

Martin J. Hunter

Commissioner of Buildings for the Boroughs of Manhattan and The Bronx.

New York, Jan 31 1900

Amendment to Application No. 2117

N. B. 1899

Location ES 78 207' E 1st Cr

1. All wood beams shall be 3" by their respective depths
 2. Girders 8x12 of steel as called for in applications.
 3. Cells Cols of 4-6"x6" L angles. bolted together as shown on new drawing
 4. 18" Heavy Cols of 4-6"x6" L angles.
 5. Floor will sustain live load of 120 lbs per sq foot.
 6. Detail 1/4" scale submitted (see new drawing)
 7. Ceiling wall shall be buttressed (see new drawings)
 8. Railing 4"x8" of iron
 9. Cols of ceiling walls of 4-6"x6" L angles
 10. Spine shall be constructed of iron & filled in with p.t.c. blocks
 11. Chicago girders shall be of 2-20"-65th steel beams.
 12. All brick work laid in cement.
 13. All Cols fire proofed with T.C. porous blocks.
 14. Depth of area wall 11'0"
 15. Steel beams 12"-40th & 2 row lock brick bonded arches in cement
 16. See drawings & amendment #3.
 17. Templates of cast iron 1/4" full and of wall & buttresses.
 18. Iron straps & foot plates as per drawings see amended drawings
 19. See amended drawings filed this date 1/31/1900.
 20. See amended drawings also refer to #3 above
 21. See #10.
 22. See #13. depth 11'0" wall in cement of brick ^{36"} at base 16" at top ~~20" at top~~
 23. See #14. bonded row lock arches & 12"-40th beams.
 24. Objections answered, including detail drawings.
 25. See #3, #8, 15.
 26. See #22. ^{36"} at base 16" at top ~~20" at top~~ of brick in cement
 27. See drawings filed 1/31/1900 for truss.
 28. See drawings giving full detail of spine construction, which shall be filed
- I have thoroughly examined the drawings relating thereto and find them in accordance with the law as to construction.
- Witness my hand and seal of the Department of Buildings, City of New York, this 6th day of February, 1900.
- Attest: J. H. Anderson
 J. H. Anderson
 J. H. Anderson

New York, May 15th 1900

Sent to Application No. 2117 N.B. 1899.

Location N.S. 7th St. 207' E of 1st Ave.

The general scheme for iron work to be used as follows and as per drawings filed herewith

1st Story columns and cellar columns running through two stories to be made of 2-8" channels $11\frac{1}{4}$ " and 2 plates $9 \times \frac{1}{4}$ "

Columns which run through cellar only to be $6 \frac{5}{8} \times 3\frac{1}{4}$ " cast iron.

Girders supporting side walls to be 2-10" I's 25 $\frac{1}{2}$ "

Bearing plates under roof trusses to be $12 \times 14 \times \frac{1}{2}$ " forming part of shoe on truss and resting on stone templets.

Construction of tower as per revised plan submitted herewith

Size of sidewalk beams 12" I's $31\frac{1}{2}$ " with skewbacks of 12" channels 20 $\frac{1}{2}$ "

Where sidewalk beam comes over doorway it is to be supported by 12" channel 20 $\frac{1}{2}$ ".



Truss details as shown on revised section filed herewith

Arthur Actander
W.

East 8th St.

Ave. A.

East 7th St.



15th Ave.

2117 May
12/21/99

DEPARTMENT OF BUILDINGS OF THE CITY OF NEW YORK.

Boroughs of Manhattan and the Bronx.

Plan No. 2117

NEW BUILDINGS OF 189

STATE OF NEW YORK
City and County of New York, } ss.:

Arthur Actauder, the Owner of premises hereinafter described, being duly sworn, deposes and says: That The Church of St. Stanislaus who resides at No. now situated at 43 & 45 Stanton Street in the City of New York, in the County of New York, is the owner in fee of all that certain lot, piece

or parcel of land, shown on the diagram annexed hereto and made a part hereof, situate, lying and being in the City and County of New York, known and designated as No. 2 103, 105, 107 & 109 East 7th Street, and bounded and described as follows, viz.:

BEGINNING at a point on the North side of 7th Street distant 207 1/2 feet East from the corner formed by the intersection of 7th Street and 1st Ave running thence N North 97 1/2 ft thence E East 72 1/2 ft thence South 15 ft thence E South 83 5/12 ft thence S West 52 5/8 feet to the point or place of beginning.

Deponent further says that the Building proposed to be erected upon the said premises in accordance with the accompanying detailed statement in writing of the specifications and plans therefor, will be erected by or on account of the following person or persons, whose full name or names, residence or residences and interest or interests are as follows:

<u>Church of St. Stanislaus</u>	No. <u>43 & 45 Stanton Street</u>
as <u>Owner</u>	
<u>Arthur Actauder</u>	No. <u>360 Alexander Ave</u>
as <u>Architect</u>	
<u>Rev John H Strzalecki</u>	No. <u>54 Stanton Street</u>
as <u>Agent</u>	
	No. _____
	No. _____
	No. _____

these being the only persons interested in said proposed Building

Sworn to before me, this 19day of December 1899.

F. Pagette Notary Public
of NY County.

Arthur Actauder

REPORT UPON APPLICATION.

Department of Buildings of the City of New York.

New York, 189

To the Superintendent of Buildings:

I respectfully report that I have thoroughly examined and measured the wall....., etc.,
named in the foregoing application, and found the foundation wall.....to be built of.....
inches thick,.....feet below curb, the upper wall.....built of.....inches thick,
.....feet deep,.....feet in height, and that the mortar in said wall.....is.....
hard and good, and that the wall.....built as party wall.....and.....in a good and safe condition.

What is the nature of the ground?.....

What kind of sand was used in the mortar?.....

(The Inspector must here state what defects, if any, are in the wall.)

(The Inspector must state the thickness of wall in each and every story.)

.....
.....
.....
.....
.....
.....
.....

Inspector.

FINAL REPORT OF INSPECTOR.

New York, May 1, 1901

To the Superintendent of Buildings:

Work was commenced on the within described building on the 21 day of April 1900
and completed on the 25 day of April 1901, and all the iron and steel girders,
beams and columns are properly set, and of size as per application, and all the work upon said building
has been done in accordance with the foregoing detailed statement, except as noted below.

Respectfully submitted,

J. E. Deegan Inspector.

REMARKS.

May 24/00 Working on basement walls P. J. Gough
Aug 16/00 Masons on gables Peter W. Hammon
Oct 1/00 Masons on front tower Jas. J. Gough
Apr 13/01 Almost completed. J. E. Deegan

DEPARTMENT OF BUILDINGS

BOROUGH OF MANHATTAN, CITY OF NEW YORK

MANHATTAN
Municipal Bldg.,
ManhattanBROOKLYN
Municipal Bldg.,
BrooklynBRONX
Bronx County Bldg.,
Grand Concourse & E. 161st St.,
BronxQUEENS
21-10 49th Avenue,
L. I. CityRICHMOND
Boro Hall,
St. George, S. I.

NOTICE—This Application must be TYPEWRITTEN and filed in TRIPlicate, and one copy sworn to by Applicant. If Elevator or Plumbing Applications are filed herewith, one affidavit is sufficient for all. Plans must be filed on tracing Linen or Cloth.

AFFIDAVIT

Received AUG 17 1938

CHECK AND
NOTED CORRECT

PERMIT No. _____ 193

APPLICATION No. 2551 1938CITY OF NEW YORK
BOROUGH OF MANHATTANLOCATION 103-107 East 7th St. North Side
208' 0" East of First Avenue.BLOCK 435 LOT 49

WARD _____ VOL. _____

New York City August 16, 1938

To THE COMMISSIONER OF BUILDINGS:

Application is hereby made for approval of the plans and specifications herewith submitted, and made a part hereof, for the building therein described,—with the understanding that if no work is performed hereunder within one year from the time of issuance, this approval shall expire by limitation as provided by law; and the applicant agrees to comply with all provisions of the Building Code of the City of New York, and with the provisions of all other laws and rules relating to the erection of said building in effect at this date.

Work under this approval will not be commenced until a permit has been secured, application for which will be filed with the Commissioner of Buildings, accompanied by satisfactory evidence that compensation insurance has been obtained in accordance with the provisions of the Workmen's Compensation Law.

EXAMINED AND RECOMMENDED FOR APPROVAL ON _____

1938

APPROVED _____ 193

Commissioner of Buildings, Borough of

STATE AND
CITY OF NEW YORK } ss.:
COUNTY OF New York

Charles S. Ward,

Typewrite Name of Applicant.

being duly sworn, deposes and says: That he resides at Number 431 West 14th Street,in the Borough of Manhattanin the City of New Yorkin the County of New YorkIn the State of New York

, that he is the Architect for the

owner in fee of all that certain lot, piece or parcel of land, shown on the diagram annexed hereto and made a part hereof, situate, lying and being in the Borough of MANHATTAN, City of New York, aforesaid, and known and designated as Number 103-107 East 7th St., 208' 0" East of First Ave., and hereinafter more particularly described: that the work proposed to be done upon the said premises, in accord-

East 7th Street and First Avenue
running thence North 97' 6" feet; thence East 77' 6" feet;
thence South 15' 1" feet; thence West 20' 2" feet;
thence South 82' 5" feet; thence West 58' 0" feet
to the point or place of beginning,—being designated on the map as Block No. 435 Lot No. 49

(SIGN HERE) _____ APPLICANT

Sworn to before me, this _____

day of _____

193
Commissioner of Deeds, N.Y.
N.Y. Co. Cks. No. 24, Res. No. 24-9
Kings Co. Cks. No. 4, Res. No. 4-102
Expires May 17, 1946

AFFIX SEAL OF
REGISTERED ARCHITECT OR
PROFESSIONAL ENGINEER
HERE

NOTE: If Building is a Multiple Dwelling the following authorization is required.

AUTHORIZATION OF OWNER

DEPOSES AND SAYS: That _____ resides at
_____ Borough of _____ City
of _____ State of _____; that he is _____ owner of
all that certain piece or lot of land situated in the Borough of _____ in the City of New York,
and located on the _____ side of _____

and known as No. _____ on said street; that the multiple dwelling proposed to be _____ upon
said premises will be constructed in accordance with the annexed specifications and plans submitted herewith for
the approval of the Department of Buildings, and that _____ is duly
authorized by said owner _____ to make application in said owner's behalf in compliance with
Chapter 713 of the Laws of 1929 for the approval of such specifications and plans.

NOTE:—This clause to be used only when the person executing this authorization is not the sole owner of the premises
described herein.

He further says that the full names and residences, street and number, of the owner or owners of the said
land, and of every person having an interest in said premises and projected multiple dwelling either as owner,
lessee, or otherwise, as required by Section 300 of the Multiple Dwelling Law, are as follows:

(Name) No. _____ (Address)
as _____
(Relation to premises)

(Name) No. _____ (Address)
as _____
(Relation to premises)

(Name) No. _____ (Address)
as _____
(Relation to premises)

Signature. _____

DEPARTMENT OF BUILDINGS

BOROUGH OF

CITY OF NEW YORK

No work under this application
shall be started in connection with
foundations until the soil has been
examined and its bearing capacity
approved by the Commissioner of
Buildings.

NOTE: All elevations and grades for curbs
and sidewalks must be obtained from
the Commissioner of Public Works.

DEPARTMENT OF HOUSING AND BUILDINGS

CITY OF NEW YORK

BOROUGH OF

DIVISION OF BUILDINGS

MANHATTAN
Municipal Bldg.
ManhattanBROOKLYN
Municipal Bldg.,
BrooklynBRONX
Bronx County Bldg.,
Grand Concourse & E. 161st St.,
BronxQUEENS
21-10 49th Avenue,
L. I. CityRICHMOND
Boro Hall
St. George, S. I.

NOTICE—This Application must be TYPEWRITTEN and filed in TRIPLICATE, and ONE copy sworn to by Applicant. A copy must be kept in plain view on the work at all times until completion.

PERMIT TO BUILD

PERMIT No. 3455 19 38 } N.B. ALT. Application No. 2551 19 38
R. & D. ELEV. SIGN

LOCATION 103-107 E. 7th. StBLOCK 435 LOT 49SEC. VOL. New York City Sept. 22, 1938 19

To the Superintendent of Buildings:

Application is hereby made for a **PERMIT** to perform the entire work described in the above numbered application and the accompanying plans. If no work is performed within one year from the time of issuance this permit shall expire by limitation as provided by law; and the applicant agrees to comply with all provisions of the Building Code of the City of New York and with the provisions of all other laws and rules relating to this subject. Compensation insurance has been secured in accordance with the requirements of the Workmen's Compensation Law as follows:

Ind. Ins. Co. of NA WC CP 18942 exp. Aug. 6th. 1939
(SEE OTHER SIDE OF THIS SHEET)

STATE & CITY OF N. Y. } ss. William Johnson man
COUNTY OF N. Y. } Typewrite Name of Applicant

being duly sworn, deposes and says: That he resides at Number 313 W. 13th. St
in the Borough of Man. in the City of N. Y., in the County of N. Y.
in the State of N. Y., that he is contractor for
owner in fee of all that certain lot, piece or parcel of land, shown on the diagram annexed to the approved application and made a part thereof, situate, lying and being in the Borough of Man., City of
New York aforesaid, and known and designated as Number 103-107 E. 7th. St

and therein more particularly described; that the work proposed to be done upon the said premises, in accordance with the approved application and accompanying plans is duly authorized by St. Stanislaus R.C. Church

and that William Johnson is duly authorized by the aforesaid owner to make application for a permit to perform said work set forth in the approved application and accompanying plans, and all the statements herein contained are true to deponent's own knowledge.

(SIGN HERE) William Johnson
Sworn to before me, this 22 day of Sept 19 38

Satisfactory evidence having been submitted as indicated above that compensation insurance has been secured in accordance with the Workmen's Compensation Law, a permit is hereby issued for the performance of the entire work described in the above numbered application and the accompanying plans.

EXAMINED AND RECOMMENDED FOR APPROVAL ON SEP 22 1938 19

Approved SEP 22 1938 19

Supt. of Buildings, Borough of Man.

CERTIFICATE OF INSURANCE


THIS IS TO CERTIFY that William Johnson & John Wasenda d/b/a William Johnson
313 West 13th Street, New York City, New York
is insured with the INDEMNITY INSURANCE CO. OF NORTH AMERICA under Policy No. CP-18942
covering Contractors Public Liability -- All work usual & necessary to the
operations of: Erection of steeple classified as: (5057) Iron or Steel Erection
N.O.C. (3440) Erection of Flagpoles, etc. (3429) Painting, Decorating or Paper
Hanging-N.O.C., etc. at 103-107 East 7th Street, New York City, New York
Policy limits are Public Liability \$5,000/10,000

The policy is for a period of Twelve months, and was issued August 6th, 1938
It is the intention of the Company that if the said policy be cancelled by the Company during its term,
five (5) days' written notice prior to such cancellation will be given to

Bernard J. Gillroy, Borough Superintendent of Buildings,
of Borough of Manhattan, Municipal Building, New York,
but in stating its intention, the Company does not assume any liability in the event of failure to give such notice.

Dated this 22nd day of September 19 38

Countersigned:


Agent.


President

1770 30M 12-31-37

I, _____ owner have contracted with _____

who are the Contractors and who will do all work except plumbing and work covered by Certificates of Insurance
as listed above. They will do all work themselves and hire no help. Plumbing will be done by _____

_____ a licensed plumber No. _____

he will do all work himself and hire no help except work covered by Insurance as filed with the Department of
Housing & Buildings as follows _____

BLOCK No. 435

LOT No. 49

APPLICATION No. 2551 1938

WARD No.

VOL. No.

LOCATION #103-107 East 7th Street, North Side
208'0" East of First Ave.,

DISTRICT (under building zone resolution) USE Business HEIGHT 1 1/2 AREA B

SPECIFICATIONS

- (1) NUMBER OF BUILDINGS TO BE ALTERED One
Any other building on lot or permit granted for one? no
Is building on front or rear of lot? front

- (2) ESTIMATED COST OF ALTERATION: \$ \$600. ✓

- (3) OCCUPANCY (in detail):

[illegible]

If building is to be occupied other than dwelling with ordinary store on the first floor, give permit number under which it was erected or legally converted.

- (4) SIZE OF EXISTING BUILDING:

At street level 50' 0"

At typical floor level same

Height 35x One

feet front
feet front
stories

92' 6"

X 35' 0"

feet deep
feet deep
feet

- (5) SIZE OF BUILDING AS ALTERED:

At street level

At typical floor level same

Height

feet front
feet front
stories

same

feet deep
feet deep
feet


- (6) CHARACTER OF PRESENT BUILDING:

Frame—

Non-fireproof— Non Fireproof.

—Fireproof—

FIRST AVE.



BLOCK 435
LOT 49

EAST 7TH ST.

#103 - 107 EAST 7TH ST.


NEW YORK CITY

ST. STANISLAUS R.C. CHURCH


2551

1938

CHAS. S. WARD
ARCHITECT
431 W 14TH ST.
NEW YORK CITY



BLOCK NO 435 LOT NO 49



DEPARTMENT OF HOUSING AND BUILDINGS
Borough of Man. City of New York

MANHATTAN BROOKLYN BRONX QUEENS RICHMOND
Municipal Bldg. Municipal Bldg. 1932 Arthur Ave. 170-57 Queens Blvd. Boro Hall
New York 7 Brooklyn 2 New York 57 Kew Gardens 15 L.I. St. George, SI

NOTICE - This Application must be TYPEWRITTEN and filed in TRIPPLICATE

BUILDING NOTICE

APPLICATION FOR MINOR STRUCTURES, MINOR ALTERATIONS AND REPAIRS, ELEVATOR REPAIRS,
DROP CURB, FIRE ESCAPES, MISCELLANEOUS

APPLICATION No. 2528 BLOCK 435 LOT 49

LOCATION #103-107 E. 7 St. N.S. 208 Ft. E. of 1st Ave.

FEEs REQUIRED FOR (Give Street Number)

DISTRICT (under building zone resolution) Use business Height 1 1/2 Area B

State and City of New York ss: County of N.Y.

William J. Minogue being duly
(Type or write Name of Applicant)

sworn deposes and says: That he resides at 17 E. 42 St. Borough of
Manhattan City of New York; that he is the agent for the (owner-lessee) of
the premises above described, and is duly authorized to make this application for
approval of the plans and specifications herewith submitted, and made a part hereof,
for the work to be done in the building therein described, with the understanding
that if no work is performed hereunder within one year from the time of issuance,
this approval shall expire by limitation as provided by law; and the applicant
agrees to comply with all provisions of the Building Code and all laws and regu-
lations applicable to the erection or alteration of said structure in effect at
this date; that the work to be done is duly authorized by the owner.

Deponent further says that the full names and residences of the owners or
lessees of said premises are:

Owner St. Stanislaus Church Address 103-07 E. 7 St., N.Y.C.
Rev. Fr. Felix E. Surent - Pastor " " " " "
Lessee Address

Sworn to before me this 30 day of April 1946 (Sign here)

Notary Public or Commissioner of Deeds If Licensed Architect or Engineer, affix seal.

WORKMEN'S COMPENSATION has been secured in accordance with the requirements of the
Workmen's Compensation Law as follows:

State proposed work in detail: To replace part of vault ceiling with
steps on 1st floor into church, to alter vault for new curb setting
and to install new opening from church into west court, all as
shown on plans filed herewith

Is this a new or old building? old
If old building, give character of construction non-fireproof Class 3
Number of stories high one
How occupied R. C. Church
Is application made to remove a violation? no
How to be occupied no change
Cost \$5,200



REMARKS OR SKETCH:

If this application is for Drop Curb Permit, DIAGRAM showing plot to be used, the relative position of the cut curb and the extent thereof, must be drawn above.

Cut curb _____ Total Splay _____
Length in Feet Length in Feet

Deposit (\$ _____), either in cash or certified check, payable to the order of the Department of Housing and Buildings, to insure the proper construction of the sidewalk and curb.

N.B.

Refer to ALT. _____ 194

Examined and Recommended

For Approval on

Sept 18 1946

T. V. Burke

Examiner

Approved

OCT 23 1946

194

Arthur J. Delane
Borough Superintendent

H. G.

Work commenced

Date signed off

194

I HEREBY CERTIFY that the above report is true in every respect and that the work indicated has been done in the manner required by the Rules and Regulations of this Department, except where reported adversely.

Signed

Inspector