

Jul 13 1875

Original
Department of Buildings

DETAILED STATEMENT OF SPECIFICATIONS
FOR
ALTERATIONS TO BUILDINGS.

No. *928* Submitted. *Aug 14th 1875*

index

LOCATION.

No. *110 2nd Ave*

Owner *Isaac Hopper Home*

Architect *C. F. Bunting*

Builder *Stephen Britt*

Referred to *B. appl* *Aug 14 1875*

Returned by Deputy Supt. *Aug 17 1875*

20th Dist. Aug. 17/75

Report *favorable.*

New York, *Aug 17 1875*

This is to Certify that I have examined the within detailed statement, together with a copy of the plans relating thereto, and find the same *to be* in accordance with the provisions of Chap. 625, Laws of 1871, relating to buildings in the City of New York, as amended by chapter 547, Laws of 1874; that the same has been *approved* (subject to the rules and regulations of the Health Department, as applied to buildings), and entered in the records of this Department.

Mary S. Bradley
Deputy Superintendent of Buildings

Referred to Inspector *5th Dist.*

August 17th 1875

Returned. *Sept 30 1875*

Blagden

Inspector.

REPORT UPON APPLICATION.

Department of Buildings,

New York, Aug 16 1875

To the Superintendent of Buildings:

I respectfully report, that I have examined the above-named premises, and find said building to be built of Brick Base & 4 stories, 50 feet in height, 26 feet front, 54 feet deep, Flat roof. The foundation walls are built of Stone, 20 inches thick; the upper walls are built of Brick 12 inches thick, and 50 feet in height from curb level.

..... independent wall, two party walls; and in a good and safe condition to be altered and enlarged in the manner proposed, and in conformity with the provisions of Chap. 625, Laws of 1871, relating to buildings in the City of New York, as amended by chapter 547 Laws of 1874.

Wm. Gaul

Supt. of Buildings.

REMARKS:

There is a 4 story & Basement Brick Building on each side (North & South) of premises

Wm. Gaul

REPORT OF INSPECTOR.

New York, Sept 25 1875

To the Superintendent of Buildings:

Work was commenced on the building described herein on the 1st day of Sept and completed on the 25 day of September, and has been done in accordance with the plans and specifications, except as noted below.

Respectfully submitted,

J. C. Coque

Inspector.

REMARKS:

Original
Fire Department, City of New York.

Bureau of Inspection of Buildings.

Detailed Statement of Specification

FOR
ALTERATIONS TO BUILDINGS.

No. *1039*, Submitted *July 17*, 1882

LOCATION
110 Second Avenue

Owner *Womens Prison Assn + Home,*

Architect

Builder *John J. Tucker,*

Referred to *Exam July 17*, 1882,

Returned by *21*, 1882

Report favorable.

Drawings inside

New York, *July 24* 1882

This is to certify that I have examined the within detailed statement, together with the copy of the plans relating thereto, and find the same *(see below)* to be in accordance with the provisions of the Laws relating to Buildings in the City of New York; that the same has been approved, and entered in the records of this Bureau.

W. J. Esterbrook
Inspector of Buildings

The outside stairs & railing if made of wood. are not approved

W. J. Esterbrook
July 24 1882 Inspector

Referred to Examiner *5th Dist*

July 24 1882

Returned *Nov. 7th* 1882

Riley

Examiner.

ALT 928-75*
ALT 1039-82*
UB 1646-06*
UB 244-15*
SR 2885-29
SR 2663-36
V 8274-41*
PRS 1169-64
BN 4535-65
COMPL 3627-67
ALT 1893-67
ALT 26-70
CC 61521

General Index—Housing and Development Administration—Department of Buildings

B-Form 114 (Rev. 6/70)