

B 449
L 51

APPLICATION FOR ERECTION OF BUILDINGS.

Application is hereby made to the Superintendent of Buildings of the City of New York, for the approval of the detailed statement of the specifications and plans herewith submitted, for the erection of the building herein described. All provisions of the Building Law shall be complied with in the erection of said building, whether specified herein or not.

NEW YORK, July 1 1893

(Sign here) Ernest N. Greis

1. State how many buildings to be erected. one
2. How occupied? If for dwelling, state the number of families. 22 families
3. What is the street or avenue and the number thereof? Give diagram of property. No. 61 East 7th Street
4. Size of lot. No. of feet front, 25.0; No. of feet rear, 25.0; No. of feet deep, 97.0
5. Size of building. No. of feet front, 25.0; No. of feet rear, 25.0; No. of feet deep, 84.0
No. of stories in height, five; No. of feet in height from curb level to highest point of roof beams, 58.0
6. What will each building cost exclusive of the lot? \$ 21000.00
7. What will be the depth of foundation walls from curb level or surface of ground? 10.0
8. Will foundation be laid on earth, sand, rock, timber or piles? earth
9. What will be the base, stone or concrete? stone If base stones, give size and thickness and how laid. 3'0" x 3'6" 8" thick lengthwise If concrete, give thickness. _____
10. What will be the sizes of piers? _____
11. What will be the sizes of the base of piers? _____
12. What will be the thickness of foundation walls? 24" stone & 20" brick Of what material constructed? Stone or brick laid in cement mortar
13. What will be the thickness of upper walls? Basement, 24" x 20" inches; 1st story, 16" inches; 2d story, 12 inches; 3d story, 12 inches; 4th story, 12 inches; 5th story, 12 inches; 6th story, _____ inches; 7th story, _____ inches, and from thence to top, _____ inches. Of what materials to be constructed? brick laid in fresh lime mortar
14. State whether independent or party walls. independent except portion of east wall
15. With what material will walls be coped? Blue stone
16. What will be the materials of front? Brick & Stone If of stone, what kind? _____
Give thickness of ashlar _____ Give thickness of backing in each story. 16" thick brick
17. Will the roof be flat, peaked or mansard? flat
18. What will be the materials of roofing? tin
19. Give size and materials of floor beams. 1st tier, steel beams 8" x 5 1/2"; 2d tier, oysme 3" x 10"; 3d tier, oysme 3" x 10"; 4th tier, oysme 3" x 10"; 5th tier, oysme 3" x 10"; 6th tier, _____; 7th tier, _____; 8th tier, _____; roof tier, oysme 3" x 9"
State distances from centres. 1st tier, 60 inches; 2d tier, 16 inches; 3d tier, 16 inches; 4th tier, 16 inches; 5th tier, 16 inches; 6th tier, _____ inches; 7th tier, _____ inches; 8th tier, _____ inches; roof tier, 18 inches.
20. If floors are to be supported by columns and girders, give the following information: Size and material of girders under 1st floor, steel beams 12" x 120 lbs under each of the upper floors, _____ Size and materials of columns under 1st floor, 5" diam wrought iron under each of the upper floors, _____
21. If the front, rear or side walls are to be supported, in whole or in part, by iron girders or lintels, give definite particulars. _____
22. If girders are to be supported by brick piers and columns, state the sizes of piers and columns. _____
23. State by whom the construction of the building is to be superintended. Architect.

If the Building is to be occupied as an Apartment or Tenement House, give the following particulars.

1. State how many families are to occupy each floor, and the whole number in the house; also, if any part is to be used as a store or for any other business purposes, state the fact, *Two families in basements four on each upper story 22 families all together*
 2. What will be the heights of ceilings? 1st story, *10'0"* feet; 2d story, *9'6"* feet; 3d story, *9'4"* feet; 4th story, *9'4"* feet; 5th story, *9'2"* feet; 6th story, _____ feet; 7th story, _____ feet.
 3. How are the hall partitions to be constructed and of what materials? *Stud partitions lathed & plastered*
 4. How many buildings are to be taken down? *one*
- Owner *L. Hiter & S. B. Reimann* Address *93 S. Market Place*
 Architect *Ernest W. Greis* Address *36 Union Square*
 Mason _____ Address _____
 Carpenter _____ Address _____

If a Wall or part of a Wall already built is to be used, fill up the following.

The undersigned gives notice that *he* intend to use the *westerly* wall of building *N. 63.7 (now party)* to the extent of *14' 0"* from front line as party wall in the erection of the building hereinbefore described, and respectfully requests that the same be examined and a permit granted therefor. The foundation wall *is* built of *stone* *20* inches thick, *10'0"* feet below curb; the upper wall *is* built of *brick*, *12* inches thick, *4'0"* feet deep, *4'5'6"* feet in height.

(Sign here) *Ernest W. Greis*

NOTE—In making application for the erection of buildings, the following drawings must be furnished: Plans of each and every story, front, rear and side elevations, and longitudinal and transverse sections. All plans must be drawn to a uniform scale, and must be on tracing cloth, properly designated and colored.

THE BUILDING LAW REQUIRES:

- 1st—That all stone walls shall be properly bonded and laid in cement mortar.
- 2d—That all skylights having a superficial area of more than nine square feet, placed in any building, shall have the sashes and frames thereof constructed of iron and glass.
- 3d—That every building which is more than two stories in height above the curb level, except dwelling-houses, hotels, school-houses and churches, shall have doors, blinds or shutters made of iron, hung to iron hanging frames, or to iron eyes built into the wall, on every window and opening above the first story thereof, excepting on the front openings of buildings fronting on streets which are more than thirty feet in width. Or the said doors, blinds or shutters may be constructed of pine or other soft wood of two thicknesses of matched boards at right angles with each other, and securely covered with tin, on both sides and edges, with folded lapped joints, the nails for fastening the same being driven inside the lap; the hinges and bolt, or latches shall be secured or fastened to the door or shutter after the same has been covered with the tin, and such doors or shutters shall be hung upon an iron frame, independent of the woodwork of the windows and doors, or two iron hinges securely fastened in the masonry; or such frames, if of wood, shall be covered with tin in the same manner as the doors and shutters.
- 4th—That outside fire escapes shall be placed on every dwelling-house occupied by or built to be occupied by three or more families above the first story, and every building already erected, or that may hereafter be erected, more than three stories in height, occupied and used as a hotel or lodging house, and every boarding house, having more than fifteen sleeping-rooms above the basement story, and every factory, mill, manufactory or workshop, hospital, asylum or institution for the care or treatment of individuals, and every building in whole or in part occupied or used as a school or place of instruction or assembly, and every office building five stories or more in height, all to be constructed as follows:

BALCONIES MUST NOT BE LESS THAN THREE FEET WIDE.

BRACKETS must not be less than $\frac{1}{4}$ x $1\frac{1}{2}$ inches wrought iron, placed edgewise, or $1\frac{1}{4}$ inch angle iron $\frac{1}{4}$ inch thick, well braced, and not more than three feet apart, and the braces to brackets must be not less than $\frac{3}{4}$ inch square wrought iron, and must extend two-thirds of the width of the respective brackets or balconies. In all cases the brackets must go through the wall, and be turned down three inches.

BRACKETS ON NEW BUILDINGS must be set as the walls are being built. When brackets are to be put on old houses, the part going through the wall shall not be less than one inch diameter, with screw nuts and washers not less than five inches square and $\frac{1}{2}$ inch thick.

TOP RAILS.—The top rail of balcony must be $1\frac{1}{4}$ inch x $\frac{1}{2}$ inch wrought iron or $1\frac{1}{4}$ inch angle iron $\frac{1}{4}$ inch thick, and in all cases must go through the walls, and be secured by nuts and 4 inch square washers, at least $\frac{3}{4}$ inch thick, and no top rail shall be connected at angles by the use of cast iron.

BOTTOM RAILS.—Bottom rails must be $1\frac{1}{4}$ inch x $\frac{3}{4}$ inch wrought iron or $1\frac{1}{4}$ inch angle iron $\frac{1}{4}$ inch thick, well laded into the wall. In frame buildings the top rails must go through the studding and be secured on the inside by washers and nuts as above.

FILLING-IN BARS.—The filling-in bars must be not less than $\frac{1}{2}$ inch round or square wrought iron, placed not more than 6 inches from centres, and well riveted to the top and bottom rails.

STAIRS.—The stairs in all cases must be not less than 18 inches wide, and constructed of $\frac{1}{4}$ x $3\frac{1}{2}$ inch wrought iron sides or strings. Steps may be of cast iron of the same width of strings, or $\frac{3}{4}$ inch round iron, double rungs, and well riveted to the strings. The stairs must be secured to a bracket on top and rest on and be secured to a bracket or extra cross bar at the bottom. All stairs must have a $\frac{3}{4}$ inch hand rail of wrought iron, well braced.

FLOORS.—The flooring of balconies must be of wrought iron $1\frac{1}{4}$ x $\frac{3}{4}$ inch slats placed not over $1\frac{1}{4}$ inches apart, and secured to iron battens $1\frac{1}{2}$ x $\frac{3}{4}$ inch, not over three feet apart and riveted at the intersection. The openings for stairways in all balconies shall not be less than 20 inches wide and 30 inches long, and have no covers.

DROP LADDERS.—Drop ladders from lower balconies where required shall not be less than 14 inches wide, and shall be made of $1\frac{1}{2}$ x $\frac{3}{4}$ inch sides and $\frac{3}{4}$ inch rungs of wrought iron. In no case shall a drop ladder be more than 12 feet in length. In no case shall the ends of balconies extend more than nine inches over the brackets.

SCUTTLE LADDERS.—Ladders to scuttles shall be constructed in all cases the same as the stairs or step-ladders from balconies of fire escapes.

THE HEIGHT OF RAILING around balconies shall not be less than two feet nine inches.

No Fire Escape will be approved by the Superintendent of Buildings if not in accordance with above specifications.

In constructing all balcony fire-escapes, the manufacturer thereof shall securely fasten thereto, in a conspicuous place, a cast iron plate having suitable raised letters on the same, to read as follows: Notice! Any person placing any incumbrance on this balcony is liable to a penalty of ten dollars and imprisonment for ten days.

- 5th—That all exterior and division or party walls over fifteen feet high, excepting where such walls are to be finished with cornices, gutters or crown mouldings, shall have parapet walls carried two feet above the roof, and shall be coped with stone, well-burnt terra-cotta or cast iron.
- 6th—That every building and the tops and sides of every dormer-window thereon shall be covered and roofed with slate, tin, copper or iron, or such other quality of fire-proof roofing as the superintendent of buildings, under his certificate, may authorize.
- 7th—That all exterior cornices shall be fire proof.
- 8th—That the stone or brick work of all smoke flues, and the chimney shafts of all furnaces, boilers, bakers' ovens, large cooking ranges and laundry stoves, and all flues used for a similar purpose, shall be at least eight inches in thickness. If there is a cast-iron or burnt clay pipe built inside of the same, with one-inch air space all around it, then the stone or brick work inclosing such pipes shall not be less than four inches in thickness.
- 9th—That before any iron or steel beam, lintel or girder intended to span an opening over ten feet in length in any building, shall be used for supporting a wall, it shall be inspected, tested and approved as provided by law.

Original

#94 (8) N.B.
7/18/93

NOTICE.—This permit expires by its own limitation six months from date of approval of the Plan by the Board of Health.

EMMONS CLARK, Secretary.

Application to the Health Department to approve Plans for Light and Ventilation of Proposed Tenement House.

In pursuance of Chapter 908 of the laws of 1867, as amended by Chapter 504 of the laws of 1879. Chapter 399 of the laws of 1880, and Chapter 84 laws of 1887, application is hereby made to the Board of Health of the Health Department of the City of New York, to approve the plans herewith submitted for Light and Ventilation of the Tenement Houses described in the following specifications, which are hereby made a part of said plans. The plans and specifications are to be construed together; but in case of any difference between them, these specifications, subject to such conditions as may be imposed by the Board of Health, are to govern.

Location N^o. 61. 7th Street Number of Buildings one
 Owner L. Peter & S.B. Heinson Address 93 St. Marks Ave
 Architect Ernest W. Greis Address 36 Union Square
 Size of Lot 97'6" x 25'0" Size of Building 25'0" x 87'0" No. of floors above cellar five
 Size of Extension — No. of floors above cellar —

Basement—how to be occupied Apartment & Storerooms

Basement Ceiling—height above sidewalk 2'8"

Cellar—how to be occupied —

Cellar Floor—depth below sidewalk —

Floors.	Cellar	Basement	1st	2d	3d	4th	5th	6th	7th
No. of Families to be on each Floor.	—	2	4	4	4	4	4	—	—
Height of Ceilings	—	8'0"	10'0"	9'6"	9'4"	9'4"	9'2"	—	—
Inside Rooms, No. on each Floor...	—	4	10	10	10	10	10	—	—

Inside Rooms, how lighted windows into lightcourts

Inside Rooms, how ventilated " " "

Halls—how lighted and ventilated " " " also skylight surch in bulkhead.

Will each Living Room communicate directly with the External Air? yes

Will each Bedroom have a Window opening directly to the External Air? yes

Size of Windows opening on Light and Air Shafts 2'8" x 6'0" & 2'6" x 6'0"

Area of Openings at top of each Light and Air Shaft same size as shaft

Height of Louvre Sides above Roof —

Size of Fanlights over all Doors 2'8" x 1'0" & 2'6" x 1'0"

Skylights, No. of Two Size 3'0" x 3'0" Where Located over dumbwaiter & stairs

Cellar—How lighted and ventilated? windows Will Cellar ceiling be plastered? brick arches

Cellar—Will it be made water-tight? yes By what means? concrete

NOTICE.—Architects, Builders and Plumbers are hereby notified that strict adherence to the plans and specifications on which this permit is granted will be required by the Board of Health, unless permission in writing has been previously given by the Board allowing their modification.

By order of the Board,
EMMONS CLARK, Secretary.

WHAT ADDITIONAL STRUCTURE, IF ANY, WILL BE ON THE LOT? none

Distance from extreme rear of House to rear line of Lot 10'6"

Distance from extreme rear of Extension to rear line of Lot

No. and Location of Water Closets Two on each floor one in basement

Dimensions of Shaft for Water Closets 1'0" x 3'0"

How arranged at Top to secure Ventilation curves 3'0" high

Size of Windows opening on Water Closet Shaft 3 square feet of stationary louver

REMARKS.

	SIZE.	AREA.	
1st Vent Shaft,	irregular	135 1/2 sq. ft.	I 2'0" x 40'3" = 80 1/2 sq. ft.
2d " " "	irregular	135 1/2 sq. ft.	II 4'0" x 12'0" = 48 sq. ft.
3d " " "	1' x 3'	3 sq. ft.	III 2'3'6" x 2'0" = 7 sq. ft.
4th " " "	- x -	- sq. ft.	IV 2'0" x 40'3" = 80 1/2 sq. ft.
Main Yard,	25'0" x 10'6"	262 1/2 sq. ft.	V 4'0" x 12'0" = 48 sq. ft.
Rear Yard,	- x -	- sq. ft.	VI 2'3'6" x 2'0" = 7 sq. ft.
Alley,	- x -	- sq. ft.	VII 1'0" x 3'0" = 3 sq. ft.
Front House,	87' x 25'	2175 sq. ft.	<u>274 sq. ft.</u>
Rear House,	- x -	- sq. ft.	
Lot,	97'6" x 25'	2437 1/2 sq. ft.	
Percentage of Lot covered.....			78

Dated July 1 1893

(Signatures of Owner and Applicant.)

Wiler & Steinmann
per Ernest W. Greig, Archt.

PERMIT.

Upon the statements contained in the foregoing application and specification, the plan for Light and Ventilation submitted therewith was approved by the Board of Health of the Health Department of the City of New York, at the meeting thereof held..... 189 , subject to the following conditions and Regulations:

SPECIAL CONDITIONS.

[NOTE.—These special conditions take precedence of all regulations.]

BOROUGH OF **Manhattan**, CITY OF **NEW YORK**

DEPARTMENT OF BUILDINGS

MANHATTAN
Municipal Bldg.,
Manhattan

BROOKLYN
Municipal Bldg.,
Brooklyn

BRONX
Bronx County Bldg.,
Grand Concourse & E. 161st St.
Bronx

QUEENS
21-10 49th Avenue
L.P. City

RICHMOND
Boro Hall,
St. George, S.J.

JUL 14 1937

NOTICE—This Application must be TYPEWRITTEN and filed in TRIPPLICATE.

Use for Specifications of "ALTERED" Buildings

ALTERED BUILDINGS

PERMIT No. 19

BLOCK No. 449

APPLICATION No. 2774 1937

LOT No. 51

WARD No.

VOL. No.

LOCATION 61 E. 7th St. N.S. 275' E. of 2nd Ave.

DISTRICT (Under building zone resolution) USE Bus. HEIGHT 1 1/2 AREA 2

SPECIFICATIONS

- (1) NUMBER OF BUILDINGS TO BE ALTERED **One**
Any other building on lot or permit granted for one? **no**
Is building on front or rear of lot? **Front**
- (2) ESTIMATED COST OF ALTERATION: \$ **3800**
- (3) OCCUPANCY (in detail): **Tenement 22 Families (Class A. Multiple Dwelling)**

STORY (include Cellar and basement)	BEFORE ALTERATION			AFTER ALTERATION				
	APTS.	ROOMS	USE	LIVE LOAD	NO. OF PERSONS	APTS.	ROOMS	USE
Basement	2	8	2 Fam.			2	8	2 Families
1st	4	14	4 Fam.			4	12	4 Families
2nd	4	14	4 Families			4	12	4 Fam.
3rd	4	14	4 fam			4	12	4 Fam.
4th	4	14	4 Fam.			4	12	4 fam
5th	4	14	4 fam			4	12	4 fam

DEPARTMENT OF BUILDINGS
 CITY OF NEW YORK

If building is to be occupied other than dwelling with ordinary store on the first floor, give permit number under which it was erected or legally converted.

- (4) SIZE OF EXISTING BUILDING:
At street level 25 feet front
At typical floor level 25 feet front
Height 5 stories 87 feet deep
- (5) SIZE OF BUILDING AS ALTERED:
At street level 25 feet front
At typical floor level 25 feet front
Height 5 stories 87 feet deep
- (6) CHARACTER OF PRESENT BUILDING:
Frame—
Non-fireproof— **non fireproof**
Fireproof—

(7) STATE GENERALLY IN WHAT MANNER THE BUILDING WILL BE ALTERED:

Build new partitions colored yellow on plans of wood studs, lath and plaster. Build new brick chimney for steam heat where shown on plans. Place new iron stairs with marble treads on all floor in place of present wood stairs. Fire retard stair and entrance halls as per Sect. 238 M.D. Law. Place new fire escapes in front of building as per Sect. 145 M.D. Law.

If the building is to be raised in height or if the occupancy is changed so that the floor loads will be increased, the following information must be given as to the EXISTING BUILDING and the thickness of existing walls and size of footings must be clearly shown on the plans.

(8) FOUNDATIONS: Character of Soil (State one of the materials as described in Building Code, Section 231, Subdivision 2)

Material of Foundation Walls
Thickness of Walls
Depth Below Curb

(9) UPPER WALLS: Material

Kind of Mortar
Any Ashlar
Thickness of Walls

(10) PARTY WALLS: Any to be used?

Thickness of Walls

If building is to be enlarged or extended, the following information as to NEW WORK must be given:

(11) FOUNDATIONS: Character of Soil (State one of the materials as described in Building Code, Section 231, Subdivision 2)

Material of Foundation Walls
Thickness of Walls
Depth Below Curb

(12) UPPER WALLS: Material

Kind of Mortar
Any Ashlar
Thickness of Walls

(13) PARTY WALLS: Any to be used?

Thickness of Walls

(14) FIREPROOFING: Material and Thickness

For Columns
For Girders
For Beams

(15) INTERIOR FINISH: Material

Floor Surface
Trim, Sash, Doors, etc.
Plaster

(16) OUTSIDE WINDOW FRAMES AND SASH: Material wood

EXAMINED AND RECOMMENDED
FOR APPROVAL ON.....

193.....

Examiner

**THE CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

MANHATTAN
Municipal Bldg.,
New York 7

BROOKLYN
Municipal Bldg.,
Brooklyn 1

BRONX
1932 Arthur Ave.,
New York 57

QUEENS
120-55 Queens Blvd.,
Kew Gardens 24, L. I.

RICHMOND
Boro Hall
St. George 1, S. I.

NOTICE - This Application must be TYPEWRITTEN and filed in TRIPLICATE.

- CHECK ONE BOX
- ORIGINAL INSTALLATION
- REPLACEMENT OR ALTERATION
(If work involves change of design of combustion chamber, maximum capacity, atomization, or grade of oil)
- OTHER THAN ABOVE

OIL BURNING EQUIPMENT

708

MAY 25 1965

APC-5 FILED APC-48 FILED

DO NOT WRITE IN THIS SPACE

N.B., ALT., OR B.N. NO. _____ 19__

BLOCK 449 LOT 51 19__

LOCATION 61 East 7th Street, N/S, 275' east of 2nd Avenue BOROUGH Man.

ALL ITEMS MUST BE FILLED IN EXCEPT WHERE OTHERWISE INDICATED

Maximum Input 2,174,000 BTU per hour Maximum Output 1,553,000 BTU per hour

Fee Computation FOR OIL BURNING EQUIPMENT \$ 50.00

FOR ERECTION OR ALTERATION OF CHIMNEY \$ _____ TOTAL \$ 50.00

FEE PAID MAY-25-65 464950 DL 708 65 50.00

TO THE BOROUGH SUPERINTENDENT Date May 10th 1965

I hereby make application for approval of the installation described herein and certify to the accuracy of the statements given in this application and the computations, plans and detailed drawings which were prepared by me or under my supervision and that to the best of my knowledge and belief the installation if made in accordance therewith, will conform to the Administrative Code, the Rules of the Board of Standards and Appeals, and the Rules of the Board of Air Pollution Control and will not conflict with any provision of the Charter, the Multiple Dwelling Law and the Labor Law, the General City Law, the Building Zone Resolution, or any other provisions of law applicable thereto, except for the following:

Clinton Brown 4804 White Plains Road, Bronx, NY

(APPLICANT) (ADDRESS)

Clinton Brown
(SIGNATURE OF APPLICANT)

Examined For Approval on NOV 10 1965 [Signature]
EXAMINER

Approved NOV 16 1965 [Signature]
BOROUGH SUPERINTENDENT

SPECIFICATIONS

Construction of building Non fireproof brick

How is building occupied? Multiple Dwelling- Class A State number of families 22

Proposed work Installation of an automatic oil burning system, existing heating plant

Name of Burner(s) Hev-E-Oil B.S. & A. Cal. No. 948-40-SA

Capacity of Tank(s) 1500 Gallons Grade of Oil 4

Will system be fully automatic? yes Name of preheater none

B.S. & A. Cal. No. -- Will preheater conform with Rule 7.2.2? --

Will all safety and operating controls be provided as per preheater? yes B.S. & A. resolution approving the burner and/or preheater? yes

Name of anti-siphon or foot valve none Name of constant level device none

Will tanks be inside or outside building? Inside

Buried or above ground? Above Will tank enclosure comply with Rule 6? yes

Any heating coils in tanks? no Will fill line comply with Rule 7.4? yes

Will vent line comply with Rule 7.3? yes

Location of shut-off valves At oil burner in supply line

Type of measuring device App'd oil gauge Name of pump Tuthill Wall Pump

Will pump of burner be below top of storage tank? No

In dwelling will automatic control be installed? --

Will damper when closed completely cut off passage of flue gases? no

Location of remote control Outside blr. rm. Labeled yes

Is ventilation adequate? yes Will fire protection comply with Rule 14? yes

Is installation along line of subway? No Will it conform with Rule 6.5.1? --

Fill Box Permit No. 4365 - 5' from curb.

4/1/65

N.B. 9-9-65

PROPOSED CONSTRUCTION WORK

Will installation include the erection or alteration of a chimney? No (YES OR NO). If answer is "yes", describe

and fill in either estimated cost \$ _____ or whether work is included in approved application _____ (N.B., ALT., OR B.N.)

No. _____. If answer is "no", fill in statement regarding construction of existing chimney. Will the tank be buried, enclosed, or installed outside the building? yes (YES OR NO). If answer is "yes", specify _____

Tank encased in 4" masonry, per Oil Burner _____. If answer to either or both of the above questions is "yes", submit this form in quadruplicate. Rules of the Board of Standards & Appeals

STATEMENT REGARDING CONSTRUCTION OF EXISTING CHIMNEY

I hereby state that I have inspected the chimney at the premises wherein under this application I propose to install oil burning equipment and found that the chimney is in good condition and has walls of _____

Brick 8"
(GIVE MATERIAL AND THICKNESS)

and lining of Fire Clay
(GIVE MATERIAL)

Paul McKay
(NAME OF P.E., OR R.A. OR LICENSED INSTALLER)

Paul McKay
(SIGNATURE)
Stuyvesant Oil Burner Corp.
412 E. 110th St., NYC
(ADDRESS)

STATEMENT OF OWNER

I hereby state that I am the sole part owner of the premises described in this application and that the premises are occupied as (61 E 7 St) Multiple Dwelling- Class A

I have authorized the applicant to file this application for the work specified herein.

If occupied as a Multiple Dwelling, also complete the following:

I hereby further state that a Central Heating Plant Did exist at these premises prior to July 1st, 1951. (DID OR DID NOT)

The owner or owners of the said premises are

Mary Zimmerman
(NAME AND RELATIONSHIP TO PREMISES)

2207 Andrews Avenue, Bronx 53, NY
(ADDRESS)

(NAME AND RELATIONSHIP TO PREMISES)

(ADDRESS)

(NAME AND RELATIONSHIP TO PREMISES)

(ADDRESS)

Mary Zimmerman
(SIGNATURE OF OWNER OR OFFICER OF CORP.)

(IF A CORPORATION, GIVE NAME AND ADDRESS OF CORPORATION ON THE FIRST LINE ABOVE AND THE NAME AND ADDRESS OF TWO OFFICERS ON THE SECOND AND THIRD LINES; AND SIGNED BY AN AUTHORIZED OFFICER OF THE CORPORATION)

WORK PERMIT

I hereby state that I will make the installation described in this application and plans, if any, approved therewith and I certify that to the best of my knowledge and belief, the installation will conform to the Administrative Code, the rules of the Board of Standards and Appeals and the rules of the Department of Air Pollution Control and I have obtained Workmen's Compensation insurance as follows:

Employers Mutual Liability Ins. Co.
INSURANCE COMPANY

0516-00-060796
POLICY NO.

1/30/66
EXPIRES

Stuyvesant Oil Burner Corp.
NAME OF INSURED

412 E. 110th Street, NYC
ADDRESS

Paul McKay
NAME OF LICENSED INSTALLER

412 E. 110th Street, NYC
ADDRESS OF LICENSED INSTALLER

License No. 1763 A
CLASS A OR B

5/31/66 Paul McKay
EXPIRES SIGNATURE OF LICENSED INSTALLER

PERMISSION IS HEREBY GRANTED TO INSTALL OIL BURNING EQUIPMENT AS DESCRIBED IN THE FOREGOING APPLICATION.

DATE OF ISSUANCE

BOROUGH SUPERINTENDENT

ISSUED BY CLERK

Falsification of any statement is an offense under Section 982-9.0 of the Administrative Code and is punishable by fine of not more than five hundred dollars (\$500.00) or imprisonment of not more than sixty (60) days or both.

FOR CONSTRUCTION INSPECTOR'S USE WHEN "PROPOSED CONSTRUCTION WORK" ABOVE, IS INVOLVED.

On _____ I inspected the subject premises and found that the construction work involved in this an-

ORIGINAL

THE CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

MANHATTAN
Municipal Bldg.,
New York 7

BROOKLYN
Municipal Bldg.,
Brooklyn 1

BRONX
1932 Arthur Ave.,
New York 57

QUEENS
120-55 Queens Blvd.,
Kew Gardens 24, L. I.

RICHMOND
Boro Hall,
St. George 1, S. I.

NOTICE - This Application must be TYPEWRITTEN and filed in TRIPLICATE

Minor Structures, Minor Alterations and Repairs, Elevator Repairs, Drop Curb, Fire Escapes, Miscellaneous

Block 449 Lot 51
DISTRICT (under building zone resolution)
Use R-7-2 Height Area
Is sidewalk shed or fence required

BUILDING NOTICE RECEIVED DEPARTMENT OF BUILDINGS DEC-3-1958 CITY OF NEW YORK DO NOT WRITE IN THIS SPACE

SIDEWALK SHED. No sidewalk shed or fence shall interfere with visibility or operation of any traffic light. The Department of Traffic shall be notified whenever such structure is to be erected within seventy five (75) feet of a traffic light. Failure to comply may be cause for revocation of this approval and any permit issued thereon.

LOCATION 61 East 7th St. W.S. 275 E. of 2nd Avenue N.Y.C. (Give Street Number)

THIS IS NOT A WORK PERMIT. A PERMIT MUST BE OBTAINED BEFORE WORK IS STARTED

State proposed work in detail: close up dumbwaiter shaft. All as per plans filed herewith for approval.

Date of Construction [X] Before 1938 [] After 1937

Indicate class of construction:

- Class 1-Fireproof Class 2-Fire protected [X] Class 3-Non-fireproof Class 4-Wood frame Class 5-Metal Class 6-Heavy timber

Number of stories high five (5) How occupied M.D.

Is application made to remove a violation? yes

How to be occupied same

Estimated Cost \$ 400

(Any variation in estimated cost shall be filed and recorded as an amendment.)

Exemptions

If exemption from payment fee is claimed, state clearly the basis of claim

Initial fee payment

2nd payment of fee to be collected before a permit is issued - Amount \$

Verified by Date

ADDITIONAL FEES REQUIRED (Yes or No) AMOUNT \$

VERIFIED BY DATE

1. The sum of the fees indicated on the first and second receipts shall represent the total fee. Any variation on contemplated work or change affecting the estimated cost shall be recorded as an amendment. If any question arises in connection with the estimated cost or with the adequacy of the fee, no permit shall be issued unless adjusted to the satisfaction of the department at the direction of the Borough Superintendent.

Bribery is a Crime: A person who gives or offers a bribe to any employee of the City of New York, or an employee who takes or solicits a bribe, is guilty of a felony punishable by imprisonment for ten years or by a fine of \$4,000, or more, or both. Penal Law, Section 378 and 1826.

REMARKS OR SKETCH :

If this application is for Drop Curb Permit, DIAGRAM showing plot to be used, the relative position of the cut curb and the extent thereof, must be drawn above.

Cut curb _____ Total Splay _____
Length in Feet Length in Feet

Deposit (\$ _____), either in cash or certified check, payable to the order of the Department of Buildings, to insure the proper construction of the sidewalk and curb.

Refer to N.B. _____
ALT _____ 19

Dominick Salvati & Son
(Typewrite Name of Applicant)

States that he resides at 175 Joralemon St. Borough of

Brooklyn City of New York; that he is the agent for the (owner-lessee) of the premises above described, and is duly authorized to make this application for approval of the plans and specifications herewith submitted, and made a part hereof, for the work to be done in the building therein described,—with the understanding that if no work is performed hereunder within one year from the time of issuance, this approval shall expire by limitation as provided by law; and the applicant agrees to comply with all provisions of the Building Code and all laws and regulations applicable to the erection or alteration of said structure in effect at this date; that the work to be done is duly authorized by the owner.

Applicant further states that the full names and residences of the owners or lessees of said premises are:

Owner Mary Zimmerman Address 4217 E. 14th St. NYC

Lessee _____ Address _____

DATED Dec 5th 1966 (Sign here) _____

Applicant

If Licensed Architect or Professional Engineer, affix seal.

AUTHORIZATION OF OWNER: I hereby state that I have authorized the applicant to file this application for the work specified herein.

Mary Zimmerman
(Signature of Owner or Officer of Corp.)

Falsification of any statement is an offense under Section 982-9.0 of the Administrative Code and is punishable by a fine of not more than five hundred dollars (\$500.00) or imprisonment of not more than sixty (60) days or both.

For Approval on JAN 24 1967 19

Joseph Macobozzo
Examiner
Joseph Macobozzo
Borough Superintendent

Approved _____ 19

Work commenced _____ Date signed off _____ 19

I hereby Certify that the above report is true in every respect and that the work indicated has been done in the manner required by the Rules and Regulations of this Department, except where reported adversely.

Signed _____