

City of the Borough President of the Borough of Manhattan,  
In The City of New York.

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

The City of New York, ..... 191.....

Amendment to Application No.

{ Alt. B,  
New B, 191

Location

- 6. Piers checked now changed and so marked on plans except where beams are substituted for Brick Bonded Piers; all as shown on plans.
- 7. Girders checked now changed and so marked on plans.
- 8. Masonry and footings increased in size.
- 9. Footings and piers will not project beyond the building lines and so shown on plans.

Respectfully,

*David Stone*

12/30/1911

*Construction*

*James A. Reid*

*[Handwritten signature]*

This is to certify that the above described  
alterations of the building and change in the  
masonry, girders, and piers, shown on the  
plans submitted at [blank] for the purpose of  
construction are in accordance with the  
requirements of the laws of the City of New York.

-2-

*[Handwritten signature]*

For.

Of **Mayor** *Frederick H. H. H. H.*  
In The City of New York.

(B) 30,000  
28 x 32

L34

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

BUREAU OF BUILDINGS  
OF THE CITY OF NEW YORK  
RECEIVED JAN 17 1912  
FOR THE BOROUGH  
OF MANHATTAN.

The City of New York, January 16th 1912

Amendment to Application No. 3221

Alt. B, 1911.  
~~Alt. B, 1911~~

Location #207 Second Ave., South-west Corner of Thirteenth Street.

It is proposed to amend by placing window in rear of southerly side wall of building proper at first story; opening to be relieved overhead by means of two 6" I beams 12#s, also window on southerly side wall of extension on first story, and similar windows to be placed in walls of basement story, window for building proper to be relieved by means of three 6" I beams 12#s. Jambs of above windows to be lined up carefully in cement mortar all properly bonded.

It is proposed to omit brick filling in opening of front wall on Second Avenue near Thirteenth Street and the four 10" I beams 4'-0" in length now shown on plan substituting four 12" I beams 31.5#s to span opening, each end bearing on wall 2'-6" all as shown on drawings.

Respectfully,

*David Stone*

*Construction*  
*Homer A. Reid*  
*J. B. Ray*

1/20/1912  
[Faint official stamp and handwritten notes]

1/22/12

L34

In The City of New York

Manhattan

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

RECEIVED  
OFFICE OF THE CLERK  
OF THE CITY OF NEW YORK  
FOR THE BUREAU OF BUILDINGS  
JAN 24 1912

The City of New York, January 24th 1912

Amendment to Application No.

3221

{ Alt. B, 1912  
{ New B, 1912

Location #207 Second Ave., South-West Corner of Thirteenth Street.

It is proposed to re-arrange stair hall of basement and first story retaining present 8" brick walls.

Hall wall of basement front to be cut away, opening to be relieved by means of two 8" I beams 18#s supported from brick wall on proper template to girder in front.

NOTE:-

Girder of front on Second Ave., supported at first story level by means of 8" X 12" cast iron column 3/4" metal; this column to be supported by means of four 10" I beams.

*1/29/1912*  
This is to certify that the above described work is in accordance with the provisions of the Building Law of the City of New York and the regulations of the Board of Building and Fire Underwriters.

Respectfully,

*David Stone*

SEAL OF THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN

Office of the Borough Engineer

New York.

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,

Office, No. 220 FOURTH AVENUE,

S. W. Corner 18th Street.

The City of New York, February 7th 1912

Amendment to Application No.

322I Alt.

{ Alt. B, 1911.  
{ ~~NEW XIXXXX~~

Location

#207 Second Ave., South-west Corner of Thirteenth Street.

It is proposed to re-arrange the stair hall of basement and first story retaining the present 8" brick walls.

Brick bonded pier 12" X 12" in cellar will be provided with girders to carry the new wall for entrance of basement.

First two arch openings in 8" division wall in cellar to be brick filled.

NOTE:-

For the angle columns two 3" X 4" X 5/16" and one plate 8" X 5/16" it is proposed to substitute Bethlehem rolled steel "H" columns weighing 34.5#s per foot with flange thickness of 1/2", flange width of 8" and a depth of 8".

For the angle columns two 3" X 4" X 1/2" and one plate 8" X 1/2" it is proposed to substitute for these latter columns Bethlehem rolled steel 8" "H" columns with a depth of 8-1/8" and a flange width of 8.04", flange thickness being 9/16" weighing 39#s.


It is proposed to substitute for the 8" X 12" cast iron column 3/4" metal for front on Second Avenue a 6-5/8" steel shell Lally Column weighing 49#s.

New corrected drawings will shortly be filed.

Respectfully,

*David Stone*

L34



28 B-42-11 (B).

the Borough President,  
In The City of New York.

Reg. of the City of New York.

BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

L34

The City of New York, February 21st 1912

Amendment to Application No. 3221

{ Alt. B. 1911.  
~~XXXXXX~~  
New B. 1912

AMEND. OF 7/2/12 IS HEREBY WITHDRAWN.

Location # 208 & #207 Second Ave., South-west Corner of Thirteenth Street.

It is proposed to amend by raising the floor of the basement of main building filling in between the present fire-proof arches and the new floor with cinders. The second tier of beams of the main building likewise will be raised.

It is proposed to re-arrange the stair hall of the new first story retaining present 8" brick walls.

Brick bonded pier 12" X 12" in cellar will be provided with girders to carry the new wall of entrance of new first story.

First two arch openings in 8" division wall in cellar to be brick filled.

New Terra Cotta block partition provided to form side of room next to hall in front on new second story.

One 8" I beam 13#s provided on new first story to carry the above.

Heights of the lower stories now changed to 10'-6" in the clear for the new first story and 10'-0" in the clear for the new second story.

Present first tier of beams of building proper consists of steel beams and concrete arches. To strengthen the above, new girder provided in cellar of building proper consisting of two 9" I beams 21#s supported by means of 5" Lally columns.

Second tier of beams of building proper 3" X 12"

Office of the Borough

In The City of New York

## THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,

Office, No. 220 FOURTH AVENUE,

S. W. Corner 18th Street.

The City of New York, ..... 191.....

L34  
Amendment to Application No.{ Alt. B,  
New B, 191**Location**

Spruce 12" centers.

It is proposed to amend by placing window in rear of southerly side wall of building proper at new second story; opening to be relieved overhead by means of two 6" I beams I2#s and similar window to be placed in wall of new first story to be relieved overhead by means of three 6" I beams I2#s. Jambs of above windows to be lined up carefully in cement mortar and all properly bonded.

It is proposed to omit brick filling in opening on front wall on Second Avenue near Thirteenth Street and the four 10" I beams 4'-0" in length now shown on plans, substituting three 12" I beams 31.5#s to span opening each end bearing on wall 2'-6" all as shown on drawings.

Grillage beams under the columns now changed to three instead of four for 10" I beams and two 18" I beams substituted for grillage of the two westerly columns on Thirteenth Street of Building proper.

**NOTE:-**

Columns and girders changed as follows:

For the angle columns four 3" X 4" X 5/16" angles and one plate 8" X 5/16" it is proposed to substitute Bethlehem rolled steel H columns weighing 34.5#s per foot with a flange thickness of 1/2" and a flange width of 8" and a depth of 8".

For the angle columns four 3" X " X 1/2" and one plate 8" X 1/2" it is proposed to substitute

Office of the Borough Engineer  
In The City of New York.

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

The City of New York, 191

L34  
Amendment to Application No.

{ Alt. B,  
{ New B, 191

Location

Bethlehem rolled steel 8# H columns with a depth of 8-1/8" and a flange width of 8.04", flange thickness of 9/16" weighing 39#s per foot.

It is proposed to substitute for the 8" X 12" cast iron column 3/4" metal for the front on Second Avenue a 6-5/8" steel shell Lally column weighing 49#s per foot.

Two cast iron 8" X 12" columns next to rear wall of main building now substituted by one 12" X 12" cast iron column 1" metal.

Center column of first story stores for extension to be 12" X 12" cast iron 1" metal and columns at rear of extension to be 8" X 12" cast iron 1" metal.

Girders for the first story of of the easterly store of extension now changed from two 10" I beams to two 12" I beams 31#s.

Present two story and cellar beams to be realized in connection with the proposed two story and one story extensions as shown on plans.

The first tier of beams for the extension at the rear will consist of steel beams with concrete arches detail of which will be filed before this part of the work is proceeded with.

8"-1# I beams will be provided for these arches of extension the same being supported in cellar of the extension by means of girder consisting of two 10" I beams 25#s extending from easterly wall to westerly wall of extension supported at center by means of 16" X 16" B.B.P.

Office of the ... the Borough ...  
In The City of New York.

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

The City of New York, ..... 191.....

L34

Amendment to Application No.

{ Alt. B,  
{ New B, 191

Location

Second tier of beams of extension will consist of  
3" X 12" Spruce 12" centers.

Roof tier to be 3" X 12" Spruce 20" centers.

Second story westerly wall of extension supported on  
girder consisting of two 8" I beams 13#s supported on the  
end by southerly wall of extension and on the other end by  
two 10" I beam girder of front and braced in center by two  
12" I beam girder 40#s, this latter girder carried

two 12" I beams 40#s supported on one end by two 6" I beams  
three feet in length resting on westerly wall of first story  
extension and on the other end by a 7" cast iron column 3/4"  
metal which in turn is supported by 16" X 16" brick bonded  
pier in cellar.

Second story of extension consists of masonry  
instead of light store front as previously shown.

New window 3'-0" X 5'-0" and also mullion window  
4'-6" X 5'-0" provided for southerly wall of first story  
extension, also window 3'-0" X 5'-0" provided for second story  
of extension in southerly wall all to be supported by  
beams of two 6" I beams 12#s and to have joints carefully  
laid in cement mortar.

Area shown on previous plans in yard now omitted and  
new area arranged on street side for store at rear of lot.

New corrected drawings now filed.





THE CITY OF NEW YORK  
 G. F. WINGS  
 BUREAU OF PERMITS  
 OF THE CITY OF NEW YORK

Value \$98

Permit No. 2427

PRESIDENT OF THE BOROUGH OF  
 BUREAU OF

Received MAY 20 1912

New York, APR 27 1912  
 BOROUGH OF MANHATTAN

In Consideration of Thirty five 00 Dollars,  
 receipt of which is acknowledged, PERMISSION IS HEREBY GIVEN to

residing at Sadie Smith  
 TO CONSTRUCT BAY WINDOW 20 ft x 2 One

said Bay Window to be 20 feet in width  
 and 20 feet in length, outside face measurement,  
 exclusive of cornices, pilasters and trim. Extent of projection to be 2nd stories. The total  
 space occupied to be 20 square feet, in payment for which the rate of  
 compensation has been fixed at 1.75 Dollars per square foot.

This permit is issued subject to the strict observance of all laws, ordinances and regulations enacted for the protection of the City so far as they may apply, and particularly to those set forth on the reverse side of this instrument, and is subject to revocation at any time by the Board of Aldermen, or in event of failure of the permittee to comply with any of the terms or conditions upon which the same is granted. The AMOUNT must be indicated by indenture on the margin.

Countersigned  
 Mallehan  
 Cashier.

President of the Borough.  
 Per [Signature]

8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35

L34

of the  
in The City of New York

BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

May 18, 1912.

The City of New York,

BUREAU OF BUILDINGS  
OF THE CITY OF NEW YORK  
Alt. Bx 191  
Received MAY 18 1912

Amendment to Application No. 3221

Location 207-2nd Ave., & 250 E. 13th St., S.W. FOR THE BOROUGH OF MANHATTAN

It is proposed to place the American Steel Wire Arch system B. as per sketch filed herewith, instead of the White System as originally filed, and approved. It is proposed to re-arrange the projection of the 2nd story show window to be 12" beyond bldg line, and permit for same filed herewith M.2427, 12, same to be contrary to approved plans.

Respectfully submitted,

Sadie Smith

By M. Smith <sup>owner</sup> Atty

5/23/1912

Dis

[Signature]

L34

In The City of New York, the Borough of Manhattan

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

RECEIVED MAY 23 1912  
FOR THE BOROUGH OF MANHATTAN

The City of New York, May 23, 1912. 191

Amendment to Application No. 3221 (Alt. B, New B, 191) 1

Location 207-2nd Ave., S.E. Cor. 13th St.

Westerly cellar wall of stable found to be 12" now lined 8" of brickwork and so shown on plans.

Side walls of main building when exposed found to be 12" and 16".

Party wall in cellar in part 16" and so corrected on plans.

By projecting show window 12". Permit from the Bureau of Highways herewith shown, M. 2427, 1912.

Stairs from new 1st story to cellar now omitted and so shown on plans. Drawings for type of arch to be used for closing opening will be similar to that use for F.P. arches of 1st tier in extension herewith filed.

Enclosure of stairs omitted in public hall on new 1st story and opening between 8" wall and vent shaft now closed with upright studs and brick filling between and now shown on plans.

All windows omitted from southerly wall of 1st story extension and so shown on plan.

Windows in southerly wall of building proper omitted on 1st and 2nd story and so shown on plans.

Partition between 1st and 2nd store from 2nd Ave., of building proper on new 1st story omitted. Two sinks of these stores omitted and one enameled iron corner basin substituted all as shown on plan.

New area way omitted in building proper on 13th St., side Dividing partition in cellar to be of board instead of plaster.

2" galv- vent pipe substituted for 3" C.I. in connection with W. C.'s of extension as marked on sec.

NOTE: substitution of floor arches.

Respectfully submitted,

David Stone

W. M. M. 5/27/12



The said land and premises above referred to are situate at, bounded and described as follows, viz. :

BEGINNING at a point on the West side of 2<sup>nd</sup> Avenue, distant \_\_\_\_\_ feet

South West from the corner formed by the intersection of East 13<sup>th</sup> Street and 2<sup>nd</sup> Avenue

running thence West 110:0" feet;

thence South 26:4 1/2" feet;

thence East 110:0" feet;

thence North 26:4 1/2" feet

to the point or place of beginning.

Lot 3335  
Block. 468

Sworn to before me, this 22<sup>nd</sup> day of May 1912 }

Sadie Smith

Philip Bader

Notary Public, \_\_\_\_\_ County.  
Spokane, Wash.

City of the Borough of Manhattan,  
The City of New York.

L34

THE BUREAU OF BUILDINGS FOR THE BOROUGH OF MANHATTAN,  
Office, No. 220 FOURTH AVENUE,  
S. W. Corner 18th Street.

The City of New York, May 27, 1912

Amendment to Application No. 3221 Alt 1911

BUREAU OF BUILDINGS  
OF THE CITY OF NEW YORK,  
received MAY 27 1912  
FOR THE BOROUGH  
OF MANHATTAN

Location 207 Second Avenue

Amendment of May 23, 1912 withdrawn.

It is hereby proposed to use and install a fireproof floor  
of concrete reinforced with Triangular Mesh Reinforcement made  
by the American Steel and Wire Company as shown as detail draw-  
ing filed herewith, instead of the White fireproof system as ori-  
ginally approved.

Show window at second story to project 12" beyond the build-  
ing line. See permit of file for projection of said window.

All as now shown on plans.

Respectfully submitted,

*Fourbridge Bards*

5/31/1912

Construction

*Howe & Rind*

*W. H. ...*

*Reardon ...*

6/1/12